

AMB intelligent bus AC monitoring device

Installation and Operation Instruction V1.4

Declaration

All rights reserved. Without the written permission of the company,the contents of any paragraphs and chapters in this manual shall not be copied,copied or reproduced or disseminated in any form. Otherwise,all consequences shall be borne by the violator.

The company reserves all legal rights.

The company reserves the right to modify the specifications described in this manual without prior notice. Before ordering, please consult your local agent for new specifications.

Contents

1.Overview	l
2.Product models	1
3. Technical parameters	1
4. Overall structure and dimensions	3
4.1 Overall dimensions	3
4.2 Installation instructions	7
5. Wiring instructions	9
5.1 Voltage and current connection	10
5.2 Mains and auxiliary power supply connections	10
6. Operation guide	12
6.1 Meaning of LED indications	12
6.2 Buzzer	12
6.3 Alarm setting	12
6.4 Centralized monitoring	12
6.5 Functions of control buttons	13
6.6 Display screens	13
6.7 Data setting on the display	14
7. Communication guide	14
7.1 General information	14
7.2 Protocol	14
7.3 Error check methods	15
7.4 Communication application	15
7.5 Communication protocol	16
8. Precautions	29
9. Diagnostics and troubleshooting of common faults	29

1.Overview

AMB intelligent bus AC monitoring device is a new development to cater for smart power bus bar. It consists of a feeding detection module and a tapping detection module and integrates functions of conventional power measurements, electricity monitoring, consumption assessment and control. It also boasts the online alarm function and enables the independent off-line operation. It monitors the bus bar interface temperature in real time.

By virtue of 2 RJ45 communication ports (1 in and 1 out) and MODBUS-RTU protocol, it is easy and reliable to upload the monitoring data to the touch screen of the main controller for centralized monitoring, ensuring safe and reliable operation of the system. The smart bus bar monitor has several benefits such as flexible and convenient wiring so that it is a good substitution of the traditional centralized array cabinet.

2.Product models

Model	Standard functions	Optional functions
AMB100-A	(1) Full electrical measurements of three-phase AC circuit, 2 nd to 63 rd	/W(LORA)
	harmonic measurements, 1 leakage current, 8-way temperature, 1-way	
	humidity, maximum demand measurement, neutral current, potential	
	difference measurement between the null line and the ground line, 2	
	digital inputs, 2 digital outputs	
AMB100-A-P1	(2) Full electrical measurements of three-phase AC circuit, 2 nd to 63 rd	
	harmonic measurements, 1 leakage current, 8-way temperature, 1-way	
	humidity,maximum demand measurement, neutral current measurement,	
	2 digital inputs, 2 digital outputs, discrete auxiliary power supply	
AMB110-A	(1) Full electrical measurements of three-phase AC circuit, 2 nd to 63 rd	
	harmonic measurements, 1 leakage current, 8-way temperature, 1-way	
	humidity,maximum demand measurement, neutral current measurement,	
	potential difference measurement between the null line and the ground	
+3 (D110 + D1	line, 2 digital inputs, 2 digital outputs	
AMB110-A-P1	(2) Full electrical measurements of three-phase AC circuit, 2 nd to 63 rd	
	harmonic measurements, 1 leakage current, 8-way temperature, 1-way	
	humidity, maximum demand measurement, neutral current measurement,	
A MD 120	2 digital inputs, 2 digital outputs, discrete auxiliary power supply	
AMB120	8-way temperature	
AMB10	Monitor; the front network port:AMB10(F), the rear network	
	port:AMB10(B&DZ),can automatically display the voltage and current	
A M (D 20)	parameters	
AMB20	AMB20-1:accessory, used with AMB100/AMB110 for network port to	
	network port transfer of intelligent bus staring box and plug-in box	
	AMB20-2:accessory, used with AMB100/AMB110 for RS485 port to	
	network port transfer of intelligent bus staring box and plug-in box	

Note 1. AMB: bus bar series; 100: for feeding cabinet; 110: for tapping cabinet; 120: for temperature detection; A: for alternating-current system; P1: discrete auxiliary power supply

Note 2. AMB10 display is optional. The display is divided into AMB10(F) with the front port and AMB10(B&DZ) with the rear port. It shows the voltage and the current in an automatic cycle.

Note 3. For optional LORA function, an external magnetic antenna is equipped. The standard length is 2 m.

Note 4. For temperature sensors, there are two round-hole variants, namely 12mm-hole variant and 8mm-hole variant, and one 6mm-cylindrical variant. Each variant includes yellow, green, red and black sensors.

3. Technical parameters

AMB100-A-□/AMB110-A-□

Measured par	rameters	Voltage, current, frequency, active power, inactive power, power factor, active energy, inactive energy, 2 nd -63 rd harmonic, temperature, leakage	
Voltage	Rated value	3x220/380VAC	
	Range	±20%	
	Overloading	1.2 times than the rated voltage value continuously or 2 times than	
		the rated voltage value instantaneously per second	
Current	CT	AMB100-A: 5A/2.5mA, 100A/20mA, 400A/100mA, 600A/100mA	
		AMB110-A: 100A/20mA	
	Range	1%-120%	

	Overloading	1.2 times than the rated current value continuously or 10 times than
7 0		the rated current value instantaneously per second
Input frequency		45-65Hz
Measurement acc	uracy	Voltage/current: grade 0.2; active power/energy: grade 0.5; inactive power/energy: grade 1; temperature: ±1°C
Auxiliary power s	supply	AMB100/110-A(/W): triggered upon receipt of request signal AMB100/110-A(/W)-P1: follow the bus bar voltage
functions	Temperature detection	-20-150°C
	Leakage	0-1A
	Digital input	2 dry-contact inputs
	Digital output	2 relay outputs; contact capacity: 3A/30VDC, 3A/250VAC
	Communication	Via RS485/Modbus-RTU or LORA antenna
Installation		Use DIN35mm rail
Protection		IP20
Pollution level		2
Environment Temperature/ humidity/ altitude		Working temperature: -20-60°C
		Storage temperature: -25-70°C
		Relative humidity: ≤93%
		Altitude: ≤2500m
Safety	Insulation	The minimum insulation resistance between all terminals and conductive components of the shell is $100M\Omega$.
	Withstanding	When a voltage of 2kV AC is applied between the voltage/ current
	voltage	input, relay output, RS485 port, auxiliary power supply and digital
		inputs, the leakage shall be less than 2mA and no breakdown or
		flashover shall occur in 1min
Electromagnetic	Electrostatic	Class 4
immunity	discharge immunity	
	Radio frequency	Class 3
	electromagnetic	
	immunity	
	Transient burst immunity	Class 4
	Surge immunity	Class 4


AMB120


Measurement accu	racy	Temperature: ±1°C	
Auxiliary power su	ıpply	220VAC, discrete	
functions	Temperature	-20-150°C	
	detection		
	Communication	Via RS485/Modbus-RTU or LORA antenna	
Installation		Use DIN35mm rail	
Protection		IP20	
Pollution level		2	
Environment	Temperature/	Working temperature: -20-60°C	
	humidity/	Storage temperature: -25-70°C	
altitude		Relative humidity: ≤93%	
		Altitude: ≤2500m	
Safety	Insulation	The minimum insulation resistance between all terminals and	
		conductive components of the shell is $100M\Omega$.	
Withstanding		When a voltage of 2kV AC is applied between the auxiliary power	
voltage		supply and temperature sensors, the leakage shall be less than 2mA	
		and no breakdown or flashover shall occur in 1 min	
Electromagnetic Electrostatic		Class 4	


immunity	discharge	
	immunity	
	Radio frequency	Class 3
	electromagnetic	
	immunity	
	Transient burst	Class 4
	immunity	
	Surge immunity	Class 4

4. Overall structure and dimensions


- 4.1 Overall dimensions
- 1) AMB smart bus bar detection module









RS485/Modbus-RTU Communication








LORA Communication


Note 1. For LORA communication, the space shall be reserved for antenna.

Note 2. An external auxiliary power supply is not required for LORA module.


2) Ancillary transformer (unit: mm)



AKH-0.66/W-12NY series transformer




AKH-0.66/W-45NY series transformer




AKH-0.66/W-30NY-250A/100mA transformer

Model	Ancillary transformer	Remark
AMB100-A-□	AKH-0.66/W-12NY 5A/2.5mA, grade 0.2	(incl. 3 transformers)
	AKH-0.66/W-12NY 100A/20mA, grade 0.2	(incl. 3 transformers)
	AKH-0.66/W-45NY 400A/100mA, grade 0.2	(incl. 3 transformers)
	AKH-0.66/W-45NY 600A/100mA, grade 0.2	(incl. 3 transformers)
	AKH-0.66/W-30NY-250A/100mA, grade 0.2	(incl. 3 transformers)
AMB110-A-□	AKH-0.66/W-12NY 100A/20mA, grade 0.2	(incl. 3 transformers)


3) AMB display (unit: mm)





4) Temperature sensor (unit: mm)

 30 ± 0.3




Temperature	End			Wire length	Suggested use
sensor	D1	D2	L1	L2	
12mm hole	12.5	18	35	2000 or 4000	With M10 and M12 screws
8mm hole	8.5	14	33		With M6 and M8 screws
6mm diameter	6.5	12	30	2000	Insert in the connection gap

2000 ± 20


Note: For each temperature sensor variant, there are yellow, green, red and black types, corresponding to phases A, B, C and N.

5) AMB20 adapter (Unit: mm)




4.2 Installation instructions

The AMB detection module is installed on DIN35mm rails and equipped with thru-hole transformer. The side with the connector is connected to Current directly.




Rail-installed Type




Installation of Ancillary Transformer

AMB display is flush-mounted. Align the display with the mounting holes, insert clips and secure the display.



Display installation mode


AMB20 adapter module is connected with the instrument through network cable.




AMB20-1 installation diagram

AMB20-2 installation diagram

5. Wiring instructions




AMB1X0-A(/W) Triggered upon Receipt of Request Signal




AMB1X0-A(/W)-P1 Discrete Auxiliary Power Supply

5.1 Voltage and current connection




AMB100/110-A-P1 (>600A)




AMB100/110-A-P1 (<600A)

Note: The direction of current shall be as indicated by arrow on the transformer.

5.2 Mains and auxiliary power supply connections



AMB1X0-A(/W)-P1 Auxiliary Power Supply



5.2.1 Temperature sensor connection

Temperature sensors shall be used to measure temperatures T1 to T8. They are NTC R25=50k (4150) thermistors. They send the monitoring signals for temperature between -20°C and 150°C and monitor the cable temperature.


Note: Temperature sensors shall be secured firmly to prevent it from short circuiting after fall.

5.2.2 Network shielded wire connection


The communication port shall be connected with RJ45 network shielded wire. To connect different detection modules, it is necessary to connect RS485(I) of a module to RS485(II) of the other module. To connect a detection module with a display, RS485(II) of the module shall be connected to RS485(I) of the display. For RJ45, two wires are adequate since MODBUS-RTU protocol is applied. Keep the copper strips of connector upward. These copper strips are numbered 1 to 8 from left to right. B is presented as 1 while A is presented as 2.



Note: It is not available if LORA is activated.



Connection of Detection Modules



Connection of Detection Module with Display

6. Operation guide

6.1 Meaning of LED indications

On an AMB smart monitor are two LEDs, Run and Alarm, indicating the monitor status. When Run turns green, it indicates that the monitor works normally. This LED flashes every 0.5 second.

When Alarm turns red, it indicates that the monitor fails. This LED flashes every 0.5 second.

6.2 Buzzer

6.2.1 Buzzer activation/ deactivation

The buzzer is activated or deactivated according to the communication parameter setting. Refer to 7.5, Communication Parameter Address List.

Set "1" to activate the buzzer and "0" to deactivate the buzzer.

The buzzer is activated by default.

6.2.2 Buzzer setting

After being activated, the buzzer alarm can be cleared according to the communication parameter setting. Refer to 7.5, Communication Parameter Address List.

Set "0x8801" to clear the current alarm. The buzzer alarm will be activated again if another alarm status occurs.

6.3 Alarm setting

AMB smart monitor boasts the online alarm function. Provide DO output and 2-stage over-current alarm by one buzzer. Enable the discrete running beyond the system. There is an on/off fault alarm (activated in 1s after the monitor is switched on or off) and an over-temperature alarm. It can also record the alarm time.

Set the specific alarm threshold according to the communication parameter setting. Refer to 7.5, Communication Parameter Address List.

Read the specific alarm status according to the communication parameter setting. Refer to the column "Alarm status" in 7.5, Communication Parameter Address List.

6.4 Centralized monitoring

Centrally acquire and monitor the data of 80-tap tapping cabinet. Acquire and show the electric parameters of each tap. Upload all acquired data to the power environment monitoring system.


Furthermore, monitor the temperature at the bus bar connection in a real-time manner. By virtue of 2 RJ45 communication connectors (1 in and 1 out) and MODBUS-RTU protocol, it is easy and secure to upload the monitored data to the main controller and the background system, ensuring the safe and reliable running of the system.

6.5 Functions of control buttons

Symbol	Designation	Functions	
FN	FN	Unavailable	
SET	SET	Select a function, switch over to another function or save	
		the selected function, or back to the last menu	
A	Up	Submenu parameters -	
▼	Down	Submenu parameters +	
4	Enter	Enter the next menu or confirm the selection	

6.6 Display screens


Measurement screens. After being powered, the display will show the voltage and the current in an automatic cycle. These screens change in the following order:



For this alternating-current instrument, there are three voltages and three currents. L1, L2 and L3 correspond to the phase A, B and C. It is known from these figures that the phase-A voltage is 220V. The current is 0A by default if not being matched.

Control screens:

Voltage/ current screens



To adjust the communication address, press SET under any item on the screen, enter "Addr" and then press

and ▲ or ▼. To adjust the baud rate, press
to return to "Addr" and then press ▲ or ▼. To look over

the check digit, press
to return to "Baud rate" and then press ▲ or ▼. Press SET to enter "Save". Press

to enter "NO". Press ▲ or ▼ to enter "YES". Press
to return to the main screen. For adjustment of the communication address, press ▼ to adjust unit parameters and ▲ for switchover of various parameters.

6.7 Data setting on the display

Following menus can be set on display screens:

Function screen	Description		
Addr	RS485 communication address		
PHN9	RS485 and RS645 communication baud rate		
ñodE	RS485 and RS645 communication modes		
ПООС	(no parity, odd parity, even parity)		
1366	Software No.		
100	Software version		
1.0 0			

7. Communication guide

7.1 General information

AMB smart monitor implements Modbus-RTU protocol "9600, 8, 1, n". "9600" is the baud rate by default and can be changed to 2400, 4800, 19200 or others via communication. Refer to 7.5, Communication Parameter Address List. "8" indicates 8 data bits. "n" indicates no parity. "1" indicates one stop bit.

Error check: CRC16 (cyclic redundancy check)

7.2 Protocol

When reaching the addressed terminal unit, a data frame will enter it through a simple "port". In this unit, the envelope of the data frame (data header) is removed and the contained data is read. If there is no error, the request of data will be executed. Then the terminal unit will generate and input its data into the removed envelope and return the data frame to the sender. The response data returned contains: the address of terminal slave unit (Address), the function executed (Function), requested data generated from the function (Data) and a CRC check digit (Check). If there is any error, no response will be made or an error indication frame will be returned.

7.2.1 Data frame format

Address	Function	Data	Check
8-Bits	8-Bits	Nx8-Bits	16-Bits

7.2.2 Address field

A data frame starts from address field that consists of one byte (8-Bits, 8 binary codes). It is from 0 to 255 in decimal, in which 1 to 247 is used in our system and the rest is reserved. It indicates the address of a terminal unit that user designates to receive the data from the master unit. The address of each terminal unit of one bus must be exclusive. Except for the addressed terminal unit, other terminal units will not respond to an inquiry containing its address. When the terminal unit returns a response, the master unit will identify it according to the slave address contained in the response signal.

7.2.3 Function field

The function field indicates the function to be executed by the addressed terminal unit. The following list gives all function codes used by AMB series as well as the meaning and role.

Code (hexadecimal system)	Meaning	Behavior
03H	Read the holding register	Acquire the current binary value from
		one or several holding registers
10H	Preset multiple registers	Load a specific binary value into a
		series of holding registers

7.2.4 Data field

The data field contains the data that is required for a terminal unit to execute a specific function or acquired by a terminal unit in response to inquiries. The data may be values, parameter addresses or set values.

When the function field requests a terminal unit to read a register, for example, the data field shall indicate the first register and the size of data to read. Content of the embedded address and the data depends on the type and the slave unit.

7.2.5 Error check (Check) field

The check field employs CRC16 check and enables both master unit and terminal unit to check transmission errors. When being transmitted from one unit to another unit, a set of data may change partly because of electrical noise or other interferences. In such case, the error check ensures that neither master unit nor slave unit responds to such change, improving the system safety, reliability and efficiency.

7.3 Error check methods

The error check (CRC) field occupies two bytes and contains one 16-bits binary value. A CRC value is calculated in the transmitting unit and loaded to the data frame. After receiving the data, the receiving unit will make a calculation again and compare the calculated CRC value with the received one. If they are different, it indicates that there is an error.

For CRC calculation, preset 1 at all bits of a 16-bits register and then operate 8 bits of each byte in the data frame and the current value of the register continuously. It is only 8 data bits of each byte to participate in CRC generation. The start bit, stop bit or parity bit, if any used, will not have an influence on CRC. After such 8 bits and the register content are operated by XOR for CRC generation, move the result to the lower bits and fill the higher bits with 0. Shift out and detect the lowest bit (LSB). If the lowest bit is 1, operate the register and a preset fixed value (0A001H) by XOR. If it is 0, no processing is required.

CRC generation process:

- 1. Preset a 16-bits register to be 0FFFFH (1 at all bits) and name it CRC register.
- 2. Operate 8 bits of the first byte in the data frame and lower bits of CRC register by XOR and return the result to CRC register.
 - 3. Move CRC register right by one bit. Fill the highest bit with 0. Shift out and detect the lowest bit.
- 4. If the lowest bit is 0, repeat step 3 (further movement). If the lowest bit is 1, operate the register and a preset fixed value (0A001H) by XOR.
 - 5. Repeat steps 3 and 4 until eight movements complete. By then, all of 8 bits are processed.
 - 6. Repeat steps 2 to 5 for the next 8 bits until all bytes are processed.
 - 7. The final CRC register value is CRC value.

In addition, CRC value can be calculated by looking up table. This method is mainly characterized by quick calculation. However, a big memory is required. Please consult relevant data for more details.

7.4 Communication application

All examples in this section are basically in the following form (hexadecimal data).

Addr	Fun	Data start	Data start		Data # of		CRC16	
		reg Hi	reg Lo	reg Hi	reg Lo	Lo	Hi	

01H	03H	00H	00H	00H	06H	С5Н	С8Н
Address	Function code	Data start	address	Number	of data read	Cyclic	redundancy check digit

7.4.1 Data reading

Example 1. Read the phase-A voltage

Inquiry data frame	01 03 00 30 00 02 65 cb
Return data frame	01 03 04 <u>43 5c 00 00</u> 2f a5

Keys:

01: slave address

03: function code

04: hexadecimal system. It is 4 in decimal. Indicate that 4-bytes data is followed.

2f a5: cyclic redundancy check digit

Data processing method:

If the data is integral, such as 08 98 for hi-voltage alarm, convert the data into a decimal value in the following formula: (8*256+9*16+8)/10.

If the data is floating, such as <u>43 5c 00 00</u> for phase-A voltage, convert the data into a decimal value by using the floating conversion tool.

Read other information inquiry frame in the same way. For information address, please refer to 6.4, Communication Parameter Addresses of Single-phase Meter.

7.4.2 Data writing

Example 1. Edit the meter address

Read-in data frame	01 10 00 00 00 01 02 <u>00 05</u> 66 53 (address changed to 5)
Return data frame	01 10 00 00 00 01 01 c9 (fail, no data frame returned)

Example 2. Control the buzzer alarm function

Read-in data frame	01 10 00 27 00 01 02 00 00 A0 87 (buzzer alarm deactivated)
	01 10 00 27 00 01 02 00 01 61 47 (buzzer alarm activated)
Return data frame	01 10 00 28 00 01 81 c1 (fail, no data frame returned)

7.5 Communication protocol

Address	Content	Data type	Bytes	Read/write	Remark
0	Address	uint16_t	2	R/W	1-247
1	Baud rate	uint16_t	2	R/W	0: 1200; 1: 2400; 2:4800; 3: 9600 4:
					19200; 5: 38400
2	Check method	uint16_t	2	R/W	0:8 N 1; 1:8 E 1; 2:8 0 1; 3:8 N 2
3	Wiring method	uint16_t	2	R/W	0: 3-phase 4-wire; 2: 3-phase 3-wire
4	Voltage ratio	uint16_t	2	R/W	1-9999
5	Current ratio	uint16_t	2	R/W	1-9999
6	Over-voltage alarm	uint16_t	2	R/W	0: off; 1: on
	on/off				
7	Over-voltage alarm	uint16_t	2	R/W	V
	setting				
8	Under-voltage alarm	uint16_t	2	R/W	0: off; 1: on
	on/off				
9	Under-voltage alarm	uint16_t	2	R/W	V
	setting				
A	Stage-1 over-current	uint16_t	2	R/W	0: off; 1: on

	alarm on/off				
В	Stage-1 over-current	uint16 t	2	R/W	0.1A
	alarm setting	umrro_t			····
С	Stage-1 under-current	uint16 t	2	R/W	0: off; 1: on
	alarm on/off	umit10_t		IV W	0: 011, 1: 011
D	Stage-1 under-current	uint16 t	2	R/W	0.1A
ש		umilo_i	2	K/W	0.1A
-	alarm setting	16		D/III	0 00 1
E	Stage-2 over-current	uint16_t	2	R/W	0: off; 1: on
	alarm on/off				
F	Stage-2 over-current	uint16_t	2	R/W	0.1A
	alarm setting				
10	Stage-2 under-current	uint16_t	2	R/W	0: off; 1: on
	alarm on/off				
11	Stage-2 under-current	uint16_t	2	R/W	0.1A
	alarm setting				
12	Over-power alarm on/off	uint16_t	2	R/W	0: off; 1: on
13	Over-power alarm setting	uint16_t	2	R/W	0.1kW
14	Over-frequency alarm	uint16 t	2	R/W	0: off; 1: on
	on/off	_			
15	Over-frequency alarm	uint16 t	2	R/W	0.1Hz
	setting	_			
16	Under-frequency alarm	uint16 t	2	R/W	0: off; 1: on
	on/off	umrro_t			
17	Under-frequency alarm	uint16 t	2	R/W	0.1Hz
1 /	setting	umitro_t		IV W	0.1112
18	Over-temperature alarm	uint16 t	2	R/W	0: off; 1: on
10	on/off	umino_t	2	IN W	0: 011, 1: 011
10		:41.6 4	12	D/W/	0.100
19	Over-temperature alarm	int16_t	2	R/W	0.1°C
	setting				
1A	Under-temperature alarm	uint16_t	2	R/W	0: off; 1: on
	on/off				
1B	Under-temperature alarm	int16_t	2	R/W	0.1°C
	setting				
1C	Humidity alarm on/off	uint16_t	2	R/W	0: off; 1: on
1D	Humidity alarm setting	uint16_t	2	R/W	0.10%
1E	Leakage alarm on/off	uint16_t	2	R/W	0: off; 1: on
1F	Leakage alarm setting	uint16_t	2	R/W	1mA
20	Null-ground potential	uint16_t	2	R/W	0: off; 1: on
	difference alarm on/off				
21	Null-ground potential	uint16_t	2	R/W	V
	difference alarm setting	_			
22	Neutral current alarm	uint16 t	2	R/W	0: off; 1: on
	on/off	· —			,
23	Neutral current alarm	uint16 t	2	R/W	A
	setting	<u>-</u> -	_		
	Setting			<u> </u>	<u> </u>

, <u> </u>	0.1S
105 101 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
	0: remote control; 1: alarm
	Number is written
_	0: off; 1: on
	0: open; 1: closed
	0: open; 1: closed
	0x8801
	0x6601: energy cleared
	0x6602: demand record cleared
	0x6603: energy record cleared
2C Year uint16_t 2 R/W	
2D Month uint16_t 2 R/W	
2E Day uint16_t 2 R/W	
2F Hour uint16_t 2 R/W	
30 Minute uint16_t 2 R/W	
31 Second uint16_t 2 R/W	
32 DI1 alarm on/off uint16_t 2 R/W (0: off; 1: on
33 DI2 alarm on/off uint16_t 2 R/W (0: off; 1: on
34 DI3 alarm on/off uint16_t 2 R/W I	Reserved
35 DI4 alarm on/off uint16_t 2 R/W I	Reserved
36 DI1 on/off status uint16_t 2 R/W 0	0: NO; 1: NC
37 DI2 on/off status uint16_t 2 R/W 0	0: NO; 1: NC
38 DI3 on/off status uint16_t 2 R/W I	Reserved
39 DI4 on/off status uint16_t 2 R/W I	Reserved
3A Open-phase alarm on/off uint16_t 2 R/W 0	0: off; 1: on
3B Phase-sequence alarm uint16_t 2 R/W 0 on/off	0: off; 1: on
	V
setting	
	0: off; 1: on
alarm on/off	
	0.1°C
alarm setting	
3F Cabinet uint16_t 2 R/W (0: off; 1: on
under-temperature alarm	
on/off	
40 Cabinet uint16_t 2 R/W (0.1°C
under-temperature alarm	
setting	
41 Active switching alarm 1 uint16_t 2 R/W	0: off; 1: on
on/off	
42 Active switching alarm 2 uint16_t 2 R/W (0: off; 1: on
on/off	
43 Active switching alarm 3 uint16_t 2 R/W	0: off; 1: on
on/off	

44	Active switching alarm 1	uint16_t	2	R/W	V
4.5	setting	16	2	D/W	T.
45	Active switching alarm 2 setting	uint16_t	2	R/W	V
46	Active switching alarm 3 setting	uint16_t	2	R/W	V
47-4F	Reserved				
50	Phase voltage Ua	float	4	R	V
51					
52	Phase voltage Ub	float	4	R	V
53					
54	Phase voltage Uc	float	4	R	V
55					
56	Line voltage Uab	float	4	R	V
57					
58	Line voltage Ubc	float	4	R	V
59					
5A	Line voltage Uca	float	4	R	V
5B					
5C	Null-ground potential	float	4	R	V
5D	difference				
5E	Frequency	float	4	R	Hz
5F					
60	Current Ia	float	4	R	A
61					
62	Current Ib	float	4	R	A
63					
64	urrent Ic	float	4	R	A
65					
66	Null current In	float	4	R	A
67					
68	Leakage current	float	4	R	mA
69					
6A	Zero-sequence current	float	4	R	A
6B					
6C	Active power Pa	float	4	R	W
6D					
6E	Active power Pb	float	4	R	W
6F					
70	Active power Pc	float	4	R	W
71					
72	Active power Ps	float	4	R	W
73					
74	Reactive power Qa	float	4	R	Var

7.5					
75					
76	Reactive power Qb	float	4	R	Var
77					
78	Reactive power Qc	float	4	R	Var
79					
7A	Reactive power Qs	float	4	R	Var
7B					
7C	Apparent power Sa	float	4	R	VA
7D					
7E	Apparent power Sb	float	4	R	VA
7F					
80	Apparent power Sc	float	4	R	VA
81					
82	Apparent power Ss	float	4	R	VA
83					
84	Phase-A power factor pfa	float	4	R	
85					
86	Phase-B power factor pfb	float	4	R	
87					
88	Phase-C power factor pfc	float	4	R	
89					
8A	Total power factor pfs	float	4	R	
8B					
8C	Active energy Epa	uint32_t	4	R	0.01kWh
8D					
8E	Active energy Epb	uint32_t	4	R	0.01kWh
8F					
90	Active energy Epc	uint32_t	4	R	0.01kWh
91					
92	Active energy Eps	uint32_t	4	R	0.01kWh
93					
94	Reactive energy Eqa	uint32_t	4	R	0.01kWh
95					
96	Reactive energy Eqb	uint32_t	4	R	0.01kWh
97					
98	Reactive energy Eqc	uint32_t	4	R	0.01kWh
99					
9A	Reactive energy Eqs	uint32_t	4	R	0.01kWh
9B					
9C	Total harmonic distortion	uint16_t	2	R	0.01%
	of phase-A voltage				
9D	Total harmonic distortion	uint16_t	2	R	0.01%
	of phase-B voltage				

9E	Total harmonic distortion of phase-C voltage	uint16_t	2	R	0.01%
9F	Total harmonic distortion	uint16 t	2	R	0.01%
91	of phase-A current	umtro_t	2	K	0.0176
A0	Total harmonic distortion	uint16_t	2	R	0.01%
	of phase-B current				
A1	Total harmonic distortion	uint16 t	2	R	0.01%
	of phase-C current				
A2	1 st -channel temperature	int16 t	2	R	0.1°C
A3	2 nd -channel temperature	int16_t	2	R	0.1°C
A4	3 rd -channel temperature	int16_t	2	R	0.1°C
A5	4 th -channel temperature	int16_t	2	R	0.1°C
A6	5 th -channel temperature	int16_t	2	R	0.1°C
A7	6 th -channel temperature	int16_t	2	R	0.1°C
A8	7 th -channel temperature	int16_t	2	R	0.1°C
A9	8 th -channel temperature	int16_t	2	R	0.1°C
AA	Cabinet humidity	uint16_t	2	R	0.10%
AB	Cabinet temperature	int16_t	2	R	0.1°C
AC	Digital input 1	uint16_t	2	R	
AD	Digital input 2	uint16 t	2	R	
AE	Digital input 3	uint16 t	2	R	
AF	Digital input 4	uint16 t	2	R	
B0	Alarm status 1	uint16 t	2	R	
B1	Alarm status 2	uint16 t	2	R	
B2	Alarm status 3	uint16 t	2	R	
В3	Alarm status 4	uint16_t	2	R	
B4	Active DI1	uint16_t	2	R	
B5	Active DI2	uint16_t	2	R	
В6	Active DI3	uint16_t	2	R	
B7-BD	Reserved				
BE	Maximum phase-A	float	4	R	V
BF	voltage demand				
C0	Time: year/month	uint16_t	2	R	
C1	Day/hour	uint16_t	2	R	
C2	Minute/bank	uint16_t	2	R	
С3	Maximum phase-B	float	4	R	V
C4	voltage demand				
C5	Time: year/month	uint16_t	2	R	
C6	Day/hour	uint16_t	2	R	
C7	Minute/bank	uint16_t	2	R	
C8	Maximum phase-C	float	4	R	V
С9	voltage demand				
CA	Time: year/month	uint16_t	2	R	
СВ	Day/hour	uint16_t	2	R	
			I .	<u> </u>	<u> </u>

CC	Minute/bank	uint16 t	2	R	
CD	Maximum phase-A	float	4	R	A
CE	current demand	110 410			
CF	Time: year/month	uint16 t	2	R	
D0	Day/hour	uint16 t	2	R	
D1	Minute/bank	uint16 t	2	R	
D2	Maximum phase-B	float	4	R	A
D3	current demand	nout			
D4	Time: year/month	uint16 t	2	R	
D5	Day/hour	uint16_t	2	R	
D6	Minute/bank	uint16 t	2	R	
D7	Maximum phase-C	float	4	R	A
D8	current demand				
D9	Time: year/month	uint16 t	2	R	
DA	Day/hour	uint16 t	2	R	
DB	Minute/bank	uint16_t	2	R	
DC	Maximum phase-A	float	4	R	W
DD	active demand	110 410			
DE	Time: year/month	uint16 t	2	R	
DF	Day/hour	uint16 t	2	R	
E0	Minute/bank	uint16_t	2	R	
E1	Maximum phase-B	float	4	R	W
E2	active demand				
E3	Time: year/month	uint16 t	2	R	
E4	Day/hour	uint16_t	2	R	
E5	Minute/bank	uint16 t	2	R	
E6	Maximum phase-C	float	4	R	W
E7	active demand				
E8	Time: year/month	uint16 t	2	R	
E9	Day/hour	uint16 t	2	R	
EA	Minute/bank	uint16 t	2	R	
EB	Maximum total active	float	4	R	W
	demand				
EC					
ED	Time: year/month	uint16_t	2	R	
EE	Day/hour	uint16_t	2	R	
EF	Minute/bank	uint16_t	2	R	
C8	Maximum phase-C	float	4	R	V
С9	voltage demand				
CA	Time: year/month	uint16_t	2	R	
СВ	Day/hour	uint16_t	2	R	
CC	Minute/bank	uint16_t	2	R	
CD	Maximum phase-A	float	4	R	A

СЕ	current demand				
CF	Time: year/month	uint16 t	2	R	
D0	Day/hour	uint16 t	2	R	
D1	Minute/bank	uint16_t	2	R	
D2	Maximum phase-B	float	4	R	A
D3	current demand				
D4	Time: year/month	uint16 t	2	R	
D5	Day/hour	uint16_t	2	R	
D6	Minute/bank	uint16_t	2	R	
D7	Maximum phase-C	float	4	R	A
D8	current demand				
D9	Time: year/month	uint16_t	2	R	
DA	Day/hour	uint16_t	2	R	
DB	Minute/bank	uint16_t	2	R	
DC	Maximum phase-A	float	4	R	W
DD	active demand				
DE	Time: year/month	uint16_t	2	R	
DF	Day/hour	uint16_t	2	R	
E0	Minute/bank	uint16_t	2	R	
E1	Maximum phase-B	float	4	R	W
E2	active demand				
E3	Time: year/month	uint16_t	2	R	
E4	Day/hour	uint16_t	2	R	
E5	Minute/bank	uint16_t	2	R	
E6	Maximum phase-C	float	4	R	W
E7	active demand				
E8	Time: year/month	uint16_t	2	R	
E9	Day/hour	uint16_t	2	R	
EA	Minute/bank	uint16_t	2	R	
EB	Maximum total active	float	4	R	W
EC	demand				
ED	Time: year/month	uint16_t	2	R	
EE	Day/hour	uint16_t	2	R	
EF	Minute/bank	uint16_t	2	R	
F0-F1	Phase-A energy of this	uint32_t	4	R	0.01kWh
	month				
F2-F3	Phase-B energy of this	uint32_t	4	R	0.01kWh
	month				
F4-F5	Phase-C energy of this	uint32_t	4	R	0.01kWh
	month				
F6-F7	Phase-A energy of last	uint32_t	4	R	0.01kWh
	month		<u> </u>		
F8-F9	Phase-B energy of last	uint32_t	4	R	0.01kWh
	month				

FA-FB	Phase-C energy of last	uint32_t	4	R	0.01kWh
FC-FD	month Dhase A sparry of last	nin+22 +	4	R	0.011-W/b
FC-FD	Phase-A energy of last two months	uint32_t	4	K	0.01kWh
FE-FF	Phase-B energy of last	uint32_t	4	R	0.01kWh
	two months	_			
100-101	Phase-C energy of last	uint32_t	4	R	0.01kWh
	two months				
102-103	Phase-A energy of last	uint32_t	4	R	0.01kWh
	three months				
104-105	Phase-B energy of last	uint32_t	4	R	0.01kWh
	three months				
106-107	Phase-C energy of last	uint32_t	4	R	0.01kWh
	three months				
108-109	Phase-A energy of last	uint32_t	4	R	0.01kWh
104 100	four months	22 .	4	D	0.011 W/I
10A-10B	Phase-B energy of last	uint32_t	4	R	0.01kWh
10C-10D	four months	nim+22 +	4	R	0.011-W/b
10C-10D	Phase-C energy of last four months	uint32_t	4	K	0.01kWh
10E-10F	Phase-A energy of last	uint32 t	4	R	0.01kWh
1012-101	five months	umi32_t	4	K	O.OTKWII
110-111	Phase-B energy of last	uint32 t	4	R	0.01kWh
110 111	five months	umts2_t			O.O.I.K.W.II
112-113	Phase-C energy of last	uint32 t	4	R	0.01kWh
	five months	_			
114-115	Phase-A energy of last	uint32 t	4	R	0.01kWh
	six months	_			
116-117	Phase-B energy of last	uint32_t	4	R	0.01kWh
	six months				
118-119	Phase-C energy of last	uint32_t	4	R	0.01kWh
	six months				
11A-11B	Phase-A energy of last	uint32_t	4	R	0.01kWh
	seven months				
11C-11D	Phase-B energy of last	uint32_t	4	R	0.01kWh
	seven months				
11E-11F	Phase-C energy of last	uint32_t	4	R	0.01kWh
120 121	seven months		4	D	0.011 W/I
120-121	Phase-A energy of last	uint32_t	4	R	0.01kWh
122-123	eight months Phase-B energy of last	uint22 +	4	R	0.01kWh
122-123	eight months	uint32_t	4	I K	O.OTKWII
124-125	Phase-C energy of last	uint32 t	4	R	0.01kWh
12 f-12J	eight months	am.52_t		IX .	O.O.I.K.III
126-127	Phase-A energy of last	uint32 t	4	R	0.01kWh
120 121	I made it energy of last	_ t	<u>. </u>	1 **	V.VIII., II

	nine months				
128-129	Phase-B energy of last	uint32 t	4	R	0.01kWh
	nine months	-			
12A-12B	Phase-C energy of last	uint32 t	4	R	0.01kWh
	nine months	-			
12C-12D	Phase-A energy of last	uint32 t	4	R	0.01kWh
	ten months	-			
12E-12F	Phase-B energy of last	uint32_t	4	R	0.01kWh
	ten months	-			
130-131	Phase-C energy of last	uint32 t	4	R	0.01kWh
	ten months	_			
132-133	Phase-A energy of last	uint32 t	4	R	0.01kWh
	eleven months	_			
134-135	Phase-B energy of last	uint32 t	4	R	0.01kWh
	eleven months	_			
136-137	Phase-C energy of last	uint32_t	4	R	0.01kWh
	eleven months	_			
138-139	Phase-A energy of last	uint32_t	4	R	0.01kWh
	twelve months				
13A-13B	Phase-B energy of last	uint32_t	4	R	0.01kWh
	twelve months				
13C-13D	Phase-C energy of last	uint32_t	4	R	0.01kWh
	twelve months				
13E-13F	Phase-A energy of this	uint32_t	4	R	0.01kWh
	year				
140-141	Phase-B energy of this	uint32_t	4	R	0.01kWh
	year				
142-143	Phase-C energy of this	uint32_t	4	R	0.01kWh
	year				
144-145	Phase-A energy of last	uint32_t	4	R	0.01kWh
	year				
146-147	Phase-B energy of last	uint32_t	4	R	0.01kWh
	year				
148-149	Phase-C energy of last	uint32_t	4	R	0.01kWh
	year				
14A	2 nd harmonic ratio of	uint16_t	2	R	0.01%
	phase-A voltage				
14B	2 nd harmonic ratio of	uint16_t	2	R	0.01%
	phase-B voltage				
14C	2 nd harmonic ratio of	uint16_t	2	R	0.01%
	phase-C voltage				
14D	2 nd harmonic ratio of	uint16_t	2	R	0.01%
	phase-A current				
14E	2 nd harmonic ratio of	uint16_t	2	R	0.01%
	phase-B current				

14F	2 nd harmonic ratio of	uint16 t	2	R	0.01%
	phase-C current	_			
150-155	3 rd harmonic ratio	uint16 t	6*2	R	0.01%
156-15B	4 th harmonic ratio	uint16 t	6*2	R	0.01%
15C-161	5 th harmonic ratio	uint16 t	6*2	R	0.01%
162-167	6 th harmonic ratio	uint16 t	6*2	R	0.01%
168-16D	7 th harmonic ratio	uint16 t	6*2	R	0.01%
16E-173	8 th harmonic ratio	uint16 t	6*2	R	0.01%
174-179	9 th harmonic ratio	uint16 t	6*2	R	0.01%
17A-17F	10 th harmonic ratio	uint16 t	6*2	R	0.01%
180-185	11 th harmonic ratio	uint16 t	6*2	R	0.01%
186-18B	12 th harmonic ratio	uint16 t	6*2	R	0.01%
18C-191	13 th harmonic ratio	uint16 t	6*2	R	0.01%
192-197	14 th harmonic ratio	uint16 t	6*2	R	0.01%
198-19D	15 th harmonic ratio	uint16 t	6*2	R	0.01%
19E-1A3	16 th harmonic ratio	uint16 t	6*2	R	0.01%
1A4-1A9	17 th harmonic ratio	uint16 t	6*2	R	0.01%
1AA-1A9	18 th harmonic ratio	uint16 t	6*2	R	0.01%
1B0-1B5	19 th harmonic ratio	uint16 t	6*2	R	0.01%
1B6-1BB	20 th harmonic ratio	uint16 t	6*2	R	0.01%
1BC-1C1	21st harmonic ratio	uint16 t	6*2	R	0.01%
1C2-1C7	22 nd harmonic ratio	uint16 t	6*2	R	0.01%
1C8-1CD	23 rd harmonic ratio	uint16 t	6*2	R	0.01%
1CE-1D3	24 th harmonic ratio	uint16 t	6*2	R	0.01%
1D4-1D9	25 th harmonic ratio	uint16_t	6*2	R	0.01%
1DA-1DF	26 th harmonic ratio	uint16_t	6*2	R	0.01%
1E0-1E5	27 th harmonic ratio	uint16 t	6*2	R	0.01%
1E6-1EB	28 th harmonic ratio	uint16 t	6*2	R	0.01%
1EC-1F1	29 th harmonic ratio	uint16 t	6*2	R	0.01%
1F2-1F7	30 th harmonic ratio	uint16 t	6*2	R	0.01%
1F8-1FD	31st harmonic ratio	uint16 t	6*2	R	0.01%
1FE-203	32 nd harmonic ratio	uint16 t	6*2	R	0.01%
204-209	33 rd harmonic ratio	uint16 t	6*2	R	0.01%
20A-20F	34 th harmonic ratio	uint16 t	6*2	R	0.01%
210-215	35 th harmonic ratio	uint16 t	6*2	R	0.01%
216-21B	36 th harmonic ratio	uint16 t	6*2	R	0.01%
21C-221	37 th harmonic ratio	uint16 t	6*2	R	0.01%
222-227	38 th harmonic ratio	uint16 t	6*2	R	0.01%
228-22D	39 th harmonic ratio	uint16 t	6*2	R	0.01%
22E-233	40 th harmonic ratio	uint16 t	6*2	R	0.01%
234-239	41 st harmonic ratio	uint16 t	6*2	R	0.01%
23A-23F	42 nd harmonic ratio	uint16 t	6*2	R	0.01%
240-245	43 rd harmonic ratio	uint16 t	6*2	R	0.01%
246-24B	44 th harmonic ratio	uint16 t	6*2	R	0.01%

24C-251	45 th harmonic ratio	uint16 t	6*2	R	0.01%
252-257	46 th harmonic ratio	uint16_t	6*2	R	0.01%
258-25D	47 th harmonic ratio	uint16_t	6*2	R	0.01%
25E-263	48 th harmonic ratio	uint16_t	6*2	R	0.01%
264-269	49 th harmonic ratio	uint16_t	6*2	R	0.01%
26A-26F	50 th harmonic ratio	uint16_t	6*2	R	0.01%
270-275	51st harmonic ratio	uint16_t	6*2	R	0.01%
276-27B	52 nd harmonic ratio	uint16_t	6*2	R	0.01%
27C-281	53 rd harmonic ratio	uint16_t	6*2	R	0.01%
282-287	54 th harmonic ratio	uint16_t	6*2	R	0.01%
288-28D	55 th harmonic ratio	uint16_t	6*2	R	0.01%
28E-293	56 th harmonic ratio	uint16_t	6*2	R	0.01%
294-299	57 th harmonic ratio	uint16_t	6*2	R	0.01%
29A-29F	58 th harmonic ratio	uint16_t	6*2	R	0.01%
2A0-2A5	59 th harmonic ratio	uint16_t	6*2	R	0.01%
2A6-2AB	60 th harmonic ratio	uint16_t	6*2	R	0.01%
2AC-2B1	61st harmonic ratio	uint16_t	6*2	R	0.01%
2B2-2B7	62 nd harmonic ratio	uint16_t	6*2	R	0.01%
2B8-2BD	63 rd harmonic ratio	uint16_t	6*2	R	0.01%

Remark: Actual energy value= energy reading * current ratio

Alarm status 1	bit0	Phase-A over-voltage alarm
	bit1	Phase-B over-voltage alarm
	bit2	Phase-C over-voltage alarm
	bit3	Phase-A under-voltage alarm
	bit4	Phase-B under-voltage alarm
	bit5	Phase-C under-voltage alarm
	bit6	Voltage open-phase alarm
	bit7	Phase-A stage-1 over-current alarm
	bit8	Phase-B stage-1 over-current alarm
	bit9	Phase-C stage-1 over-current alarm
	bit10	Phase-A stage-2 over-current alarm
	bit11	Phase-B stage-2 over-current alarm
	bit12	Phase-C stage-2 over-current alarm
	bit13	Phase-A stage-1 under-current alarm
	bit14	Phase-B stage-1 under-current alarm
	bit15	Phase-C stage-1 under-current alarm

Alarm status 2	bit0	Phase-A stage-2 under-current alarm
	bit1	Phase-B stage-2 under-current alarm
	bit2	Phase-C stage-2 under-current alarm
	bit3	Phase-A over-power alarm
	bit4	Phase-B over-power alarm
	bit5	Phase-C over-power alarm
	bit6	

bit7	Humidity alarm
bit8	Leakage 1 alarm
bit9	Null-ground potential difference alarm
bit10	Neutral current alarm
bit11	Phase sequence alarm
bit12	Digital input 1 alarm
bit13	Digital input 2 alarm
bit14	Cabinet over-temperature alarm
bit15	Cabinet under-temperature alarm

Alarm status 3	bit0	1st-channel over-temperature alarm
	bit1	2 nd -channel over-temperature alarm
	bit2	3 rd - channel over-temperature alarm
	bit3	4 th - channel over-temperature alarm
	bit4	5 th - channel over-temperature alarm
	bit5	6 th - channel over-temperature alarm
	bit6	7th- channel over-temperature alarm
	bit7	8th- channel over-temperature alarm
	bit8	1st-channel under-temperature alarm
	bit9	2 nd -channel under -temperature alarm
	bit10	3 rd - channel under -temperature alarm
	bit11	4 th - channel under -temperature alarm
	bit12	5 th - channel under -temperature alarm
	bit13	6 th - channel under -temperature alarm
	bit14	7th- channel under -temperature alarm
	bit15	8 th - channel under -temperature alarm

Alarm status 4	bit0	Digital input alarm 3 (none)
	bit1	Digital input alarm 4 (none)
	bit2	Active DI1 alarm
	bit3	Active DI2 alarm
	bit4	Active DI3 alarm
	bit5	
	bit6	
	bit7	Over-frequency alarm
	bit8	Under-frequency alarm
	bit9	
	bit10	
	bit11	
	bit12	
	bit13	
	bit14	
	bit15	

8. Precautions

- 8.1 The monitor shall be installed at a place without direct exposure to rain, snow, corrosive gases or violent vibration.
- 8.2 The monitor shall be installed with the surrounding temperature between -20°C and +60°C.
- 8.3 The monitor shall be installed with the surrounding relative humidity not exceeding 95%.

9. Diagnostics and troubleshooting of common faults

- 9.1 Incorrect measurements
- * Check if the voltage and current connection is correct.
- 9.2 Correct voltage and current measurements and incorrect power measurement
- *Check if the direction of current is correct.
- * Check if each current circuit corresponds to the correct phase.
- 9.3 Communication failure
- * Check if the communication connection is normal.
- * Check if the address setting and the communication baud rate are correct.
- * Check the communication of one monitor in a series of monitors with communication failure

Revision history

Date	Old version	New version	Revision
20.4.27		V1.0	1.1st issue
	V1.0	V1.1	1.Update the outline drawing of AMB10 display
			2.Correct some errors in the text
			3.Add operation instructions of AMB10 display
20.8.12	V1.1	V1.2	1.Add the outline drawing of temperature sensor
			2.Add the P1 model and transformer model
			3.Delete the data center and small typeface
			4.Correct some errors in figures
20.12.23	V1.2	V1.3	1.Revise the description of 6mm-diameter cylindrical
			temperature sensor
2022.4.27	V1.3	V1.4	1.Change AMB1X0 size diagram, add the content of
			AMB20 bus transfer module

Headquarters: Acrel Co., LTD.

Address: No.253 Yulv Road Jiading District, Shanghai, China

TEL.: 0086-21-69158338 0086-21-69156052 0086-21-59156392 0086-21-69156971

Fax: 0086-21-69158303

Web-site: www.acrel-electric.com E-mail: ACREL008@vip.163.com

Postcode: 201801

Manufacturer: Jiangsu Acrel Electrical Manufacturing Co., LTD.

Address: No.5 Dongmeng Road, Dongmeng industrial Park, Nanzha Street, Jiangyin City, Jiangsu

Province, China

TEL: 0086-510-86179966 Fax: 0086-510-86179975 Web-site: www.jsacrel.com

Postcode: 214405

E-mail: sales@email.acrel.cn