

产品认证证书

II型自愿认证

证书编号: CQC2011010309491485

发证日期: 2021年10月08日

有效期至: 2031年10月08日

委托人名称 安科瑞电气股份有限公司
及注册地址 上海市嘉定区育绿路 253 号

制造商名称 安科瑞电气股份有限公司
及注册地址 上海市嘉定区育绿路 253 号

生产企业名称 江苏安科瑞电器制造有限公司
及生产地址 江阴市南闸街道东盟路 5 号

产品名称和系列、规格、型号 电动机保护器
ARD2,ARD2L
Ui:380V;Ue:AC380;Uimp:4kV;Ie:0.4A-1.6A,1.6A-6.3A,6.3A-25A,25A-100A,63A-250A;脱扣级别:10A,10,20,30;极数:3P;防护等级:IP20; 配用的辅助触头(3NO,1NC):Ui:250V;Uimp:4kV;Ith:6A;AC-15;Ue:AC220V/Ie:3A.

产品标准和技术要求 GB/T 14048.4-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020 年 05 月 19 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

徐军

谢肇煦



中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010309491485

Valid from: Oct.08,2021

Valid until: Oct.08,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ACREL Co., Ltd. No.253 YuLv Road, JiaDing District, ShangHai City,P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ACREL Co., Ltd. No.253 YuLv Road, JiaDing District, ShangHai City,P.R.China
NAME AND LOCATION OF THE FACTORY	Jiangsu ACREL Electric MFG. Co., Ltd. No.31 HongTu Road, NanZha Street, JiangYin City
PRODUCT NAME, MODEL AND SPECIFICATION	Motor Protector ARD2,ARD2L Ui:380V;Ue:AC380;Uimp:4kV;Ie:0.4A-1.6A,1.6A-6.3A,6.3A-25A,25A-100A,63A-250A;Trip level:10A,10,20,30;poles:3P;Protection level:IP20; Auxiliary contacts for use(3NO,1NC);Ui:250V;Uimp:4kV;Ith:6A;AC-15;Ue:AC220V/Ie:3A.
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.4-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: May.19,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

徐军

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

II型自愿认证

证书编号: CQC20111010309491485

第1页 共1页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 105647

型号的解释:

ARD 2 □ - □ / □

(1) (2) (3) (4) (5)

- (1): 企业代号:安科瑞电气股份有限公司
(2): 设计序号: 2-基本型
(3): 显示代号: 空白-数码管显示; L-液晶屏显示
(4): 额定电流, 整定电流范围见表1
(5): 附加功能代号, 见表2

表1 额定电流

互感器额定电流	整定电流范围
1.6A	0.4~1.6A
6.3A	1.6~6.3A
25A	6.3~25A
100A	25~100A
250A	63~250A

表2 附加功能

附加功能	代号
通讯	C
漏电保护	L
模拟量输出	M
开关量输入	K
事件记录	SR
报警输出	J



中国质量认证中心

